



Inspection Report

STATE UNIVERSITY OF NEW YORK
SUNY DOWNSTATE MEDICAL CENTER
450 CLARKSON AVENUE, BOX 47

Customer ID: **294**
Certificate: **21-R-0021**
Site: 001

BROOKLYN, NY 11203

SUNY DOWNSTATE MEDICAL CENTER
Type: ROUTINE INSPECTION
Date: Jan-07-2009

3.56 (c)

SANITATION.

Item Housekeeping 3.56c New

Premises shall be kept clean and in good repair to facilitate good husbandry practices

In room 8-4 the pressure reducing valve used for the hose that washes down the room is leaking causing water to accumulate

Facilitate needs to repair pressure valve leak.

Correct by 1/21/09

3.84 (c)

REPEAT

CLEANING, SANITIZATION, HOUSEKEEPING, AND PEST CONTROL.

This was focused inspection to review those items that were cited on the inspection of Oct 31, 2008

Item Housekeeping 3.84c Repeat

Premises including building and grounds where housing facilities are located must be kept clean and in good repair to facilitate good husbandry practices.

Area around the light frame in the corridor outside of rm 9-22 is cracking and the ceiling outside rm 9-4 is peeling and cracking.

Light cover in the corridor outside rm 9-40 is cracked and needs to be repaired.

Primate rm 9-42 and 9-40 has areas of cracked and peeling ceiling that need to be repaired.

Clean side of cage washer has an area of the ceiling that is cracked.

Surgical prep rm on the 8th floor has a ceiling tile with water damage and needs to be replaed and in the room there is one area that is missing a ceiling tile

Cage storage rm 8-24 has an area that is blistering and needs to be repaired

Facility needs to repair surfaces to maintain good husbandry practices.

Prepared By:

JOHN LOPINTO, D V M USDA, APHIS, Animal Care

Date:

Title: VETERINARY MEDICAL OFFICER Inspector 1008

Jan-07-2009

Received By:

(b)(6), (b)(7)(c)

Date:

Title:

Jan-07-2009